




Typical Particle Size Analysis and Properties Filter Well Point Sand

US Standard Sieve	% Passing
4	99.6
6	98.7
8	96.3
10	94.1
12	90.1
16	72.5
20	51.0
30	25.1
40	7.8
50	2.2
70	1.4
100	0.4
140	0.1
Pan	0.0
Fineness Modulus	3.04
Effective Size	0.44
Uniformity Co-efficient	2.34

These do not represent a specification

Plant Office
651 Keuka Road
Edgar, FL 32149



SINCE 1892

Corporate Office
Post Office Box 3033
Davenport, FL 33836